

15.00**ARTICLE XV
SANITATION REQUIREMENTS****15.10 COUNTY HEALTH ORDINANCE.**

Compliance shall be had with all provisions of the County Health Ordinance in force in Grand Traverse County entitled "Sanitary Code of Minimum Standards Regulating Sewage Disposal, Water Supplies and Sanitation of Habitable Buildings in Grand Traverse County Michigan" as the same may be amended from time to time and violation of any provision of that Ordinance shall constitute a violation of this Ordinance.

15.11 DISTANCE OF SYSTEM FROM ANY BODY OF WATER.

Every subsurface disposal system shall be located at least one hundred (100) feet from the ordinary high water mark of any body of water.

15.12 OVERFLOW.

Under no conditions may the overflow or effluent from any septic tank or any other sewage wastes from any existing or hereafter constructed premises be discharged on the surface of the ground. The underside of the drainage bed of every subsurface disposal system shall be located at least four (4) feet above the ordinary high water level of any body of water, bay or stream. All effluent from all septic tanks located within (50) feet of the ordinary high water mark of any body of water shall be discharged in tile fields or drainage beds.

15.13 SEPTIC TANK CAPACITY.

The following minimum drainage for septic tanks shall be required: one or two bedroom dwelling - seven hundred fifty (750) gallons; three bedroom dwelling - one thousand (1,000) gallons, four or more bedroom dwelling - twelve hundred fifty (1,250) gallons.